

Corporation Park

11 On Lai Street, Shatin, New Territories

has achieved the below ratings under the
Zero-Carbon-Ready Building Certification Scheme -
Target Setting Certificate

Existing Building - EUI Pathway
Assessment Year : 2021
Target Year : 2030



YEAR 2021

LOW

YEAR 2030

**SUPER
LOW**

**YEAR 2030
LANDLORD**



**LANDLORD
YEAR 2021**



Dr CHEUNG Tin-cheung, SBS

Chairman

Hong Kong Green Building Council Limited

Energy Performance

	This Building's EUI in 2021 (kWh/m ²)	EUI Range of Rating Level (kWh/m ²)
Landlord	111.6	95.5 - 116.3

Issue Date: 4 Nov 2024
Valid Till : 3 Nov 2031

- Performance is measured in Energy Utilisation Index (kWh/m²) and calculated through the Energy Performance Calculator
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.
- Target minimum 10% reduction at target year vs assessment year

Certificate No: **zcr-ts-2411040005**