

Shatin Galleria

18-24 Shan Mei Street, Fotan, Shatin,
New Territories

has achieved the below ratings under the
Zero-Carbon-Ready Building Certification Scheme -
Energy Performance Certificate
Existing Building - EUI Pathway



**LANDLORD
EXTRA
LOW**



▲
LANDLORD



Dr CHEUNG Tin-cheung, SBS

Chairman
Hong Kong Green Building Council Limited

Energy Performance

	This Building's EUI in 2023 (kWh/m ²)	EUI Range of Rating Level (kWh/m ²)
Landlord	93.5	90.6 - 110.2

Issue Date: 4 Nov 2024
Valid Till: 3 Nov 2027

- Performance is measured in Energy Utilisation Index (kWh/m²) and calculated through the Energy Performance Calculator
EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.

Certificate No: **zcr-eb-2411040078**