

CITIC Tower


1, Tim Mei Avenue, Central, Hong Kong

has achieved the below ratings under the
Zero-Carbon-Ready Building Certification Scheme -
Energy Performance Certificate
Existing Building - EUI Pathway



**LANDLORD
SUPER
LOW**

LANDLORD

Dr CHEUNG Tin-cheung, SBS

Chairman

Hong Kong Green Building Council Limited

Energy Performance

	This Building's EUI in 2021 (kWh/m ²)	EUI Range of Rating Level (kWh/m ²)
Landlord	77.6	41.7 - 77.8

Issue Date: 11 Mar 2024
Valid Till: 10 Mar 2027

- Performance is measured in Energy Utilisation Index (kWh/m²) and calculated through the Energy Performance Calculator
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.

Certificate No: **zcr-eb-2401250045**