

# Shui On Centre

6-8 Harbour Road, Wan Chai, Hong Kong

has achieved the below ratings under the  
Zero-Carbon-Ready Building Certification Scheme -  
Target Setting Certificate

Existing Building - EUI Pathway  
Assessment Year : 2021  
Target Year : 2030

**ZERO-CARBON  
READY**  
Building Certification



**YEAR 2021**

**LOW**

**YEAR 2030**

**EXTRA  
LOW**

**YEAR 2030  
Landlord**




Low

Extra Low

Super Low

Zero-Carbon-Ready

**Landlord  
YEAR 2021**

**Dr CHEUNG Tin-cheung, SBS**

Chairman  
Hong Kong Green Building Council Limited

## Energy Performance

	This Building's EUI in 2021 (kWh/m <sup>2</sup> )	EUI Range of Rating Level (kWh/m <sup>2</sup> )
Landlord	98.8	94.9 - 115.6

Issue Date: 11 Mar 2024  
Valid Till : 31 Dec 2031

- Performance is measured in Energy Utilisation Index (kWh/m<sup>2</sup>) and calculated through the Energy Performance Calculator.
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.
- Target to achieve minimum the next level rating improvement.
- Target minimum 10% reduction at target year vs assessment year

Certificate No: **zcr-ts-2402010003**