

# Alexandra House

18 Chater Road, Central, Hong Kong

has achieved the below ratings under the  
Zero-Carbon-Ready Building Certification Scheme -  
Target Setting Certificate

Existing Building - EUI Pathway  
Assessment Year : 2021  
Target Year : 2030



**YEAR 2021**

**LOW**


**YEAR 2030**

**EXTRA  
LOW**

**YEAR 2030  
WHOLE BUILDING**



**WHOLE BUILDING  
YEAR 2021**



**Dr CHEUNG Tin-cheung, SBS**

Chairman

Hong Kong Green Building Council Limited

## Energy Performance

	This Building's EUI in 2021 (kWh/m <sup>2</sup> )	EUI Range of Rating Level (kWh/m <sup>2</sup> )
Whole Building	200.1	187.5 - 225.2

Issue Date: 26 Sep 2023  
Valid Till : 25 Sep 2031

- Performance is measured in Energy Utilisation Index (kWh/m<sup>2</sup>) and calculated through the Energy Performance Calculator
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.
- Target to achieve minimum the next level rating improvement.
- Target minimum 10% reduction at target year vs assessment year

Certificate No: **zcr-ts-2309260002**