

Cambridge House

Taikoo Place, 979 King's Road, Quarry Bay, Hong Kong

has achieved the below ratings under the
Zero-Carbon-Ready Building Certification Scheme -
Energy Performance Certificate
Existing Building - EUI Pathway



LANDLORD

LOW


WHOLE BUILDING

LOW

LANDLORD



WHOLE BUILDING



Dr CHEUNG Tin-cheung, SBS

Chairman
Hong Kong Green Building Council Limited

Energy Performance

| | This Building's EUI in 2021 (kWh/m ²) | EUI Range of Rating Level (kWh/m ²) |
|----------------|--|--|
| Landlord | 108.5 | 90.0 - 110.0 |
| Whole Building | 182.4 | 170.0 - 205.0 |

Issue Date: 26 Sep 2023
Valid Till: 25 Sep 2026

- Performance is measured in Energy Utilisation Index (kWh/m²) and calculated through the Energy Performance Calculator
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.

Certificate No: **zcr-eb-2309260014**