

Devon House

Taikoo Place, 979 King's Road, Quarry Bay, Hong Kong

has achieved the below ratings under the
Zero-Carbon-Ready Building Certification Scheme -
Energy Performance Certificate
Existing Building - EUI Pathway



LANDLORD
**EXTRA
LOW**

WHOLE BUILDING
**EXTRA
LOW**




Dr CHEUNG Tin-cheung, SBS
Chairman
Hong Kong Green Building Council Limited

Energy Performance

	This Building's EUI in 2021 (kWh/m ²)	EUI Range of Rating Level (kWh/m ²)
Landlord	81.5	76.5 - 91.9
Whole Building	160.8	142.9 - 173.8

Issue Date: 26 Sep 2023
Valid Till: 25 Sep 2026

- Performance is measured in Energy Utilisation Index (kWh/m²) and calculated through the Energy Performance Calculator
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.