

# One Pacific Place

88 Queensway, Hong Kong

has achieved the below ratings under the  
Zero-Carbon-Ready Building Certification Scheme -  
Energy Performance Certificate  
Existing Building - EUI Pathway

**ZERO-CARBON  
READY**  
Building Certification



**LANDLORD**  
**SUPER  
LOW**

**WHOLE BUILDING**  
**LOW**

**LANDLORD**



**WHOLE BUILDING**



**Dr CHEUNG Tin-cheung, SBS**

Chairman  
Hong Kong Green Building Council Limited

**Energy Performance**

	This Building's EUI in 2021 (kWh/m <sup>2</sup> )	EUI Range of Rating Level (kWh/m <sup>2</sup> )
Landlord	72.2	40.0 - 75.0
Whole Building	170.8	170.0 - 205.0

Issue Date: 26 Sep 2023  
Valid Till: 25 Sep 2026

- Performance is measured in Energy Utilisation Index (kWh/m<sup>2</sup>) and calculated through the Energy Performance Calculator
- EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.

Certificate No: **zcr-eb-2309260020**