

Prince's Building



10 Chater Road, Central, Hong Kong

has achieved the below ratings under the
Zero-Carbon-Ready Building Certification Scheme -
Energy Performance Certificate
Existing Building - EUI Pathway



LANDLORD
**SUPER
LOW**

WHOLE BUILDING
**SUPER
LOW**

Dr CHEUNG Tin-cheung, SBS
Chairman
Hong Kong Green Building Council Limited

Energy Performance

	This Building's EUI in 2021 (kWh/m ²)	EUI Range of Rating Level (kWh/m ²)
Landlord	71.2	48.7 - 89.4
Whole Building	149.2	97.3 - 168.8

Issue Date: 26 Sep 2023
Valid Till: 25 Sep 2026

- Performance is measured in Energy Utilisation Index (kWh/m²) and calculated through the Energy Performance Calculator
EUI Range of Rating Level refers to the adjusted benchmark EUI value for the corresponding rating level according to the usage type breakdown of the actual building.